

CERTIFICATE OF COMPLIANCE

Certificate Number 20211209-R40600
Report Reference R25568-20210416
Issue Date 2021-December-09

Issued to: Fire Door Solutions L L C
7500 W 160th St
Stilwell, KS 66085 USA

**This certificate confirms that
representative samples of**

Miscellaneous Fire Door Accessories
FireDoorCaulk

Fire Door Caulk, Model FireDoorCaulk, for installation to fill through-holes present in steel frames, steel and wood composite core doors, rated up to and including 1-1/2 hour.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:
Additional Information:

ANSI/UL 10B, "Fire Tests of Door Assemblies."
See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

